

NFPA 101

CHAPTER 7: MEANS OF EGRESS

7.10 Marking of Means of Egress

7.10.1.2.1 Exits, other than the main exterior exit doors that obviously and clearly are identifiable exits, shall be marked by an approved sign that is readily visible from any direction of exit access.

7.10.1.2.2 Horizontal components of the egress path within an exit enclosure shall be marked by approved exit or directional exit signs where the continuation of the egress path is not obvious.

7.10.7.1 Listing. Internally illuminated exit signs shall be listed in accordance with UL 924.

7.10.7.2 Photoluminescent Signs. The face of a photoluminescent signs shall be continually illuminated while the building is occupied. The charging light source, shall be of a type specified in the product markings.

7.10.9.1 & 2 Inspection and Testing according to **7.9.3 – Periodic Testing of Emergency Lighting Equipment.** Monthly testing of electrical exit signs for at least 30 seconds and yearly testing for at least 90 minutes. Intended to test the performance of the sign in normal conditions and the battery & lamps when the electricity fails.